



**June 21, 2022
Addendum #1
FOR IMMEDIATE ATTENTION**

ADDENDUM NO. 1 TO ALL BIDDERS:

Reference – Invitation for Bid: HVAC Replacement-Gatewood PEEP Academy
IFB# 029-0-2022/AP
For Delivery To: Newport News Public Schools
Bids Due: **Tuesday, June 28 , 2022 at 3:00 PM EST**

The above referenced IFB is hereby amended and clarified as follows:

This addendum includes the following: Carryover of note in drawings on the specified page.

1. **Drawings:** The following note below from Sheet ED 1.2 shall be added to sheet ED 1.1:

1 REINSTALL ALL CEILING MOUNTED EXIT LIGHTS, LIGHT FIXTURES, LIGHT SENSOR DEVICE ASSOCIATED WITH LIGHT FIXTURES, PROJECTORS, PROJECTOR RECEPTACLES, SMOKE DETECTORS, FIRE ALARM NOTIFICATION DEVICES, MOTION DETECTORS, CEILING MOUNTED SPEAKERS AND WIRELESS ACCESS POINTS SAVED DURING DEMOLITION IN NEW CEILING IN ORIGINAL LOCATIONS AND RECONNECT TO EXISTING BRANCH CIRCUITRY SAVED DURING DEMOLITION. EXTEND EXISTING BRANCH CIRCUITRY AS REQUIRED. PROVIDE NEW ANNEALED, LIGHT ZINC-COATED FINISH, 12-GAUGE WIRE FROM ALL FOUR CORNERS TIED TO BUILDING STRUCTURAL MEMBERS FOR ALL RECESSED LIGHT FIXTURES. SECURING SAFETY WIRES TO BRIDGING IS NOT ACCEPTABLE. THE SUPPORTING WIRES SHALL BE DISTINGUISHABLE BY COLOR OR TAGGING. PROVIDE ROD HANGERS CAPABLE OF SUPPORTING TWICE THE WEIGHT OF THE FIXTURES SUPPORTED BY THE ROD HANGER FOR ALL SURFACE MOUNTED LIGHT FIXTURES. ROD HANGERS SHALL BE A MINIMUM .18" DIAMETER. COORDINATE NEW LIGHT FIXTURE SUPPORTS WITH NEW DUCTWORK AND PIPING AND ADJUST AS DIRECTED BY THE MECHANICAL CONTRACTOR.

All other provisions of the IFB shall remain unchanged.

Sincerely,
Antonio Palmer, MBA, CPPB, VCA
Senior Procurement Specialist
757-591-7493 x10755

Name of Firm

Signature/Title

Date